

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1336

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1349 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

Smart Connect Multiloop 26 port, 1-16 Loop Analogue Addressable and Conventional Control and Indicating Equipment with Printer

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Zeta Alarms Limited
Detection House
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom

Zeta Alarms Limited
Detection House
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 Control and Indicating Equipment EN 54-4:1997 + A1:2002 + A2:2006 Power Supply Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 10 December 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



E. Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Limited

Date of First Issue: 10 December 2021

Issue Date: 10 December 2021

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1336

Smart Connect Multiloop 26 port, 1-16 Loop Analogue Addressable and Conventional Control and Indicating Equipment with Printer

Incorporating the following modules:

| | |
|------------------|-----------------------------|
| MMP-DISP | Display PCB |
| MMP-TERM | Termination PCB |
| MMP-TERM/EXP | 5 x Term Expander – 4 port |
| PCB/MMP-ZLX64 | Zone LED Expansion PCB |
| PCB/PSU-UL-15 | Power Supply Controller |
| BLD-400-V030-NNU | uPowerTek Power Supply Unit |
| SCM-LCM | Loop Card Module |
| SCM-ACM | Alarm Circuit Module |
| SCM-ZMM | Six Way Zone Monitor Module |

Optional modules:

| | |
|---------|----------------------------|
| SCM-NM | Network Module |
| SCM-MIM | Six Way Multi Input Module |
| SCM-RM | Three Way Relay Module |
| SCM-PM | Printer Module |

Ancillaries:

SMART/REP Smart Connect Multiloop LCD repeater

Incorporating the following modules:

| | |
|-------------|----------------------------|
| MMP-DISP | Display PCB |
| MMP-REP_COM | Repeater communication PCB |



E. Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Limited

Date of First Issue: 10 December 2021

Issue Date: 10 December 2021

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1336**Smart Connect Multiloop 26 port, 1-16 Loop Analogue Addressable and Conventional Control and Indicating Equipment with Printer**

Certified with the following options with requirements from EN 54-2: 1997:

- 7.8 Output to fire alarm device(s)
- 7.11 Delays to outputs
- 7.12.2 Dependencies on more than one alarm signal -Type B
- 7.12.3 Dependencies on more than one alarm signal -Type C
- 8.3 Fault signals from points
- 9.5 Disabling of each address point
- 10 Test condition

Notes:

1. Scope of approval does not include the operation of the network functionality.
2. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.



E. Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Limited

Date of First Issue: 10 December 2021

Issue Date: 10 December 2021

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com