

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00458

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): **Input / Output Modules Incorporating Short Circuit Isolators**
(refer to attached appendix for details and conditions)

Placed on the market **Zeta Alarms Limited**
under the name or trade mark of: 72/78 Morfa Road, Swansea, SA1 2EN, United Kingdom

and produced in the **Zeta Alarms Limited (SG- 15601)**
manufacturing plant(s): 72/78 Morfa Road, Swansea, SA1 2EN, United Kingdom

Intended use: **Fire Safety**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-18:2005+AC:2007
EN 54-17:2005+AC:2007


Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00458** on **2015-01-15** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body
0905

Certification Manager: Dipl.-Ing. Roland Heine **Date Issue:** 2019-10-21

Signature:



Issue: 1



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00458

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00458

The details and conditions of use for the Input / Output Modules Incorporating Short Circuit Isolators , placed on the market under the name or trade mark of:

Zeta Alarms Limited

72/78 Morfa Road, Swansea, SA1 2EN, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-18:2005+AC:2007 and EN 54-17:2005+AC:2007

Model	Manufacturing Location	Description
ZAI-MI	SG- 15601	Addressable input module with short circuit isolator
ZAIO-MI	SG- 15601	Addressable input / output module with short circuit isolator
ZASC-MI	SG- 15601	Addressable sounder control module with short circuit isolator
ZAZM-MI	SG- 15601	Addressable zone monitor module with short circuit isolator

Conditions of use:

Suitable for indoor applications

General Notes:

1. Evaluated under Intertek project number 101509912.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.
3. Model ZAI-MI, ZAIO-MI, ZAZM-MI and ZASC-MI designed to be used with suitable compatible CIE.
4. ZASC-MI requires a connected 24 VDC supply for operation. If powering EN54 devices, an EN54-4 compliant PSE (power supply equipment) is required.